

# From Carbon Accounting to Carbon Management

## Case Study on Net-Zero Industry Transformation

WinterSchool on Corporate Climate Management

Modul 3, 01<sup>st</sup> of April 2022

Dr. Michael Knaus

Head of International Department, Institute for applied Material Flow Management (IfaS)

Senior Climate Experts, DEG - Deutsche Investitions- und Entwicklungsgesellschaft mbH

**KFW** DEG

**IfaS**

# REC Coach: Institute for applied Material Flow Management



- University of Applied Sciences Trier
- Non-Profit Institute
- Foundation in 2001
- 9 Professors & 80 Employees
- Interdisciplinary Team
  - Ecological Economics
  - Mechanical & Electrical Engineering
  - Policy Science
  - Spatial Planning
  - Agriculture & Forestry Engineering
  - Environmental Law

# Coaching for Circular Economy & net-zero transformation



International Project Management



Study and Qualification



Fundraising



Biomass and Cultural Landscape Development



Energy Efficiency & Renewable Energies



E-mobility




Material Flow Management and Zero Emission




PR – Communication and Participation


- Support the planning and implementation of (ISO) management and reporting systems, e.g.:
  - GHG accounting, reporting and management
  - Energy-, GHG-, Environment management
- Benchmark analysis of environmental impacts and carbon intensity of peers, sectoral initiatives, NDCs and EU taxonomy
- Definition of (SBTi) decarbonization pathways with KPI's, interventions points Technical and economical feasibility studies
- (Renewable) Energy (efficiency), water, resource (waste) project development, incl. tender design, supplier research and evaluation
- **Education & Capacity development**

# Global REC experiences in various sectors











# IfaS Method | Energy and resource management



## Material Flow Analysis


(Status Quo)

- Inventory of consumer
- Process and consumption analysis
- Load and demand profiles
- Measurements
- Benchmarking
- .....





# 3 Scopes of GHG Protocol – Corporate Standard



# Climate Targets of Fortune 500 – The New Normal



**CARBON NEUTRAL<sup>1</sup>**

Achieved when a company completely offsets its greenhouse gas emissions.

**RENEWABLE 100% (RE100)**

Achieved when a company relies on 100% renewable energy.



### SCIENCE BASED TARGETS (SBT)


Emissions are reduced in line with the need to keep global warming below 2 degrees Celsius.

Note: This data was aggregated from various sources throughout 2020, and as a result, may not include the latest climate commitments announced by other Fortune Global 500 companies.



Countries represented


23



- Improved reputation and customer relation
- Active risk and compliance management
  - Improved relations with regulators
- Improved innovation, competitiveness and market positioning
- Enhanced operational and OPEX efficiencies (including supply chains)
- (Better) Access to capital (Trend Divestment)
- Building and sustaining shareholder value
- Enhanced ability to address change

Source: <https://www.visualcapitalist.com/climate-targets-of-fortune-500-companies/>

# Science Based (Climate) Targets (SBTi)



## Fast recognition and application of SBTi by Top-500

- Whether SBTi is manifested as a global standard is subject to be seen
- New SBT for new sectors are constantly added

GHG Protocol Corporate Standard (GHG PCS) is widely recognized and applied as GHG accounting standard

Various reporting/disclosure standards


Next step after GHG inventory and target setting are investments!




# Carbon Pricing Initiatives: Global rapid developments

64 carbon pricing instruments (CPIs) in operation covering 21.7% of global GHG emissions

127 countries, 823 cities, 101 regions, and 2,169 companies have committed to decarbonizing their activities by midcentury






## Market trends:

Averaged internal carbon price of 29 USD/tCO<sub>2e</sub> (with max. 140 USD/tCO<sub>2e</sub>) applied at global food and beverage brands

## Motivations:


- Stress test for investments
- Simulation of potential compliance impacts on economic KPIs
- Comparison of internal marginal abatement costs with carbon shadow prices as a new KPI
- Drive low carbon investments



- SBTi based decarbonisation pathway demands removal of residual GHG emissions
- Different market price ranges for sustainable removal certificates
- Increasing market demand will result in increasing prices for removals
- Competitive advantages for early birds



# | Management Process Requirements



1. Short term targets and commitments within the company
  - Renewable energy
  - GHG intensity
2. Long term net zero targets for company and value chain
  - Determining WACI and residual emission level
3. Beyond value chain mitigation
  - Scope 3 – double accounting
4. Neutralization of residual emissions


# Starting point: Carbon Accounting



# 3 Scopes of GHG Protocol – Corporate Standard

## Methodology

The GHG Protocol




Data based on clients' KPI 2021  
(Energy) and CSR 2020 (GHG; Water)

Production (Baseline Year 2021)		
Beer production	1.748.244	hl
Drinks production (Water + Soft Drinks)	1.633.480	hl
Total beverage production	3.381.724	hl
Total Water extraction	9.187.466	hl
Total HFO Consumption	2.606.375	l
Total Diesel Consumption	1.736.607	l
Total LPG Consumption	607.250	l
Electricity consumption (Grid)	19.218.542	kWh
Electricity consumption (PV)	2.463.316	kWh
Total Electricity consumption	21.681.858	kWh

Emissions		
Scope 1		
HFO consumption	8.111.038	kg CO <sub>2e</sub> /a
Diesel consumption	4.555.120	kg CO <sub>2e</sub> /a
LPG consumption	978.887	kg CO <sub>2e</sub> /a
<b>Total Energy consumption</b>	<b>13.645.045</b>	kg CO <sub>2e</sub> /a
Wastewater treatment	164.000	kg CO <sub>2e</sub> /a
Waste	232.000	kg CO <sub>2e</sub> /a
Transportation	6.724.000	kg CO <sub>2e</sub> /a
Use of Refrigerant	1.352.000	kg CO <sub>2e</sub> /a
<b>Total Scope 1</b>	<b>22.117.045</b>	kg CO <sub>2e</sub> /a
Scope 2		
<b>Purchased electricity</b>	<b>13.260.794</b>	kg CO <sub>2e</sub> /a
Scope 3		
<b>Total Upstream Scope 3 Emissions</b>	<b>25.050.138</b>	kg CO <sub>2e</sub> /a
<b>Total Downstream Scope 3 Emissions</b>	<b>tbc</b>	kg CO <sub>2e</sub> /a

Scope	Emissions (t CO <sub>2e</sub> )	%
Scope 1	22.117	36,6%
Scope 2	13.261	21,9%
Scope 3 - Upstream	25.050	41,5%
Scope 3 - Downstream	0	0,0%



Diesel and LPG consumption data is different in two sources.  
Emission balance is based on the initial data received by the client

## General GHG inventory remarks:

1. Attempt to create a GHG start balance in accordance to SBTi and GHG PCS
2. Scope 3 needs to be reported if, significant: Criteria > 40% of total GHG emissions
3. Literature and peer review indicate that Scope 3 in "Beer & Beverage Sector" ranges between 60 – 85%
4. SBTi requests for individual Scope 3 targets but no removal (yet)



## | Parts of Scope 3- upstream inventory

Total upstream emission - Scope 3				
Main Material(s)	Consumption		Material Emission factor	Emissions
	Value	Unit	kg CO2e/Unit	kg CO2e
Glass	6.711.360	kg	1,25	8.410.742
Barley				
Malt	21.098.000	kg	0,11	2.236.388
Sorghum	694.948	kg	0,25	173.737
Rice	6.746.580	kg	0,60	4.047.948
Cans (Aluminum)	1.176.350	kg	8,53	10.034.266
PET	903.570	kg	0,06	57.015
HDPE	160.790	kg	0,56	90.042
Paper				0,00
Cardboard				0,00
Plastik beer boxes				0,00
				0,00
Total Upstream Emissions (SC-3)		25.050.138	kg CO2e	
		25.050	t CO2e	

- Start with scope 3 accounting (only upstream emissions) to determine significance (>40% of total GHG)
- Based on (available) clients procurement data and LCA benchmark values of peers and eco-invent database
- Exemplary Scope 3 – upstream emissions exceed >40% threshold already



## | (Significant) Variations in product EF/WACI

Beer – KPIs (per hl <sub>beer</sub> )				
	Unit	Calculated	Client	Client target
Water consumption (72.4% from total water)	hl/hl	3,80	3,46	3,67
HFO consumption	l/hl	1,49	1,48	1,55
Electricity consumption (88.6% from total elec.)	kWh/hl	10,99	10,06	10,20
Electricity consumption (88.6% from Grid supply)	kWh/hl	9,74		
Soft drinks – KPIs (per hl <sub>softdrinks</sub> )				
	Unit	Calculated	Client	Client target
Water consumption (27.6% from total water)	hl/hl	1,55	1,41	1,38
Electricity consumption (11.4% from total elec.)	kWh/hl	1,51	1,39	1,6
Electricity consumption (11.4% from Grid supply)	kWh/hl	1,34		
Beer emission factor	kg CO <sub>2e</sub> / hl	11,36	(Grid electricity and HFO only)	
Soft drink emission factor	kg CO <sub>2e</sub> / hl	0,93	(Grid electricity only)	

- Client CSR: one aggregated EF for total production (beer and soft drinks)
  - 9,12 KgCO<sub>2e</sub>/hl
  - excluding Scope 3
- Significantly different product EFs revealed by source-attribution of energy related GHGs

BAU		
Total Production in baseline year	3.381.724	hl
Production growth	3,93%	/a

Beverage emission factor (Total production) – kg CO <sub>2e</sub> /hl		
Client value	9,12	kg CO <sub>2e</sub> /hl
Calculated (Total Scope 1 and 2)	10,46	kg CO <sub>2e</sub> /hl


Year	Emissions (Client EF)	Emissions (Calculated EF)
2021	30.841	35.378
2022	32.053	36.768
2023	33.313	38.213
2024	34.622	39.715
2025	35.983	41.276
2026	37.397	42.898
2027	38.867	44.584
2028	40.394	46.336
2029	41.982	48.157
2030	43.632	50.049
2031	45.346	52.016
2032	47.128	54.061
2033	48.981	56.185
2034	50.906	58.393
2035	52.906	60.688
2036	54.985	63.073
2037	57.146	65.552
2038	59.392	68.128
2039	61.726	70.806
2040	64.152	73.588

## KPI: Doubling the production until 2040


Compound annual growth rate (CAGR) of 3,93%/y

Clients EF: GHG increase from 30.841 tCO<sub>2e</sub>/y to 64.152 tCO<sub>2e</sub>/y in 2040


Consultants EF: GHG increase from 35.378 tCO<sub>2e</sub>/y to 73.588 tCO<sub>2e</sub>/y in 2040



# Identify systemic efficiency potentials



# Comparison Disk versus Longfield LED



Longfield LED is a product  
of Lanz Manufaktur

High-bay Lights VS Longfield			
Parameter	[Unit]	Disc	Lanz
Power Rating	W	240	120
Ballast Losses	%	8%	
Number of units	x	250	250
Total installed capacity	kW	64,8	30,0
Annual operating time	h/a	4.380	4.380
Annual elec. consumption	kWh/a	283.824	131.400
Energy savings	kWh/a		152.424
Electricity Price	USD/kWh	0,15	0,15
Annual electricity costs	USD/a	42.574	19.710
Cost savings <b>OPEX</b>	USD/a		22.864
Price per LED unit	USD/x	400	650
Total Invest	USD	100.000	162.500
<b>OPEX Payback Period</b>	<b>a</b>		<b>2,7</b>
Life Span	h	21.900	48.000
Investment at equal life span	USD	219.178	162.500
Cost savings <b>CAPEX</b>	USD		56.678




T8-LED is a product of Lanz Manufaktur with a guaranteed life expectancy of 75.000 operating hours

T8 Tubes			
Parameter	[Unit]	CrediCorp	Lanz
Power Rating	W	18	16
Ballast Losses	%	10%	
Number of units	x	1.000	1.000
Total installed capacity	kW	19,8	16,0
Annual operating time	h/a	4.380	4.380
Annual electricity consumption	kWh/a	86.724	70.080
Energy savings	kWh/a		16.644
Electricity Price	USD/kWh	0,15	0,15
Annual electricity costs	USD/a	13.009	10.512
Cost savings <b>OPEX</b>	USD/a		2.497
Price per LED unit	USD/x	18	24
Total Invest	USD	18.000	24.000
<b>OPEX Payback Period</b>	<b>a</b>		<b>2,4</b>
Life Span	h	12.000	64.000
Investment at equal life span	USD	96.000	24.000
Cost savings <b>CAPEX</b>	USD		72.000






- DIN EN 12462-1: Light and lighting – Lighting of work places – Part 1: Indoor work
  - Storage areas: maintained illuminance 150 lx, CRI 60
  - Operation areas: maintained illuminance 200 lx, CRI 80
- Recommendation: **avoid CCT higher than 5000 K**
  - Reduce exposition to blue light for long periods
  - Minimization of negative health risks (e.g. irritated sight, fatigue and headaches)
  - Protection of good eye health – **healthy retina**
- Dynamic natural light has a direct effect on the human circadian rhythm (sleep-wake rhythm)
  - ↑ Illuminance and blue light components increase until midday
  - ↓ Then they slowly decrease again until evening







Efficiency potentials in precise dimensioning, automatization and modularisation by variable speed drives/frequency inverter



Position	Industrial	Bottling	Brewhouse	Unit
Capacity <small>(based on interims inventory with data gaps)</small>	617	212	1.290	kW
Total electricity demand of pump motors	2.100			kW
Current efficiency ( $\eta$ ) level	55% - 90% (new pump-set)			%
Average pump efficiency improvement ( $\eta$ )	19%			%
Potential reduction of electricity demand	396			kW
Theoretical electrical work saving potential <small>(Assumption: 6,400 operating hours/a and 400 kW)</small>	2.560			MWh/a
Theoretical monetary saving potential <small>(Assumption: 0,15 USD / kWh)</small>	384.000			USD/a
GHG mitigation potential <small>(Assumption: 0,631 t CO<sub>2e</sub> / MWh)</small>	1.615			t CO <sub>2e</sub>

CCS Simplified  $\text{NH}_3$  Scheme**Plate-and-shell heat exchanger (PSHE)**

- Load reduction for condenser
- Heat utilisation for make-up water and CIP



# Cooling | Ammonia (NH<sub>3</sub>) heat recovery

Parameter	Unit	VSM 701	VRS 700	VCM-450XL	VSS-601	VSM-701	VML-6A	VML-6A	SUM
Nominal Displacement	m <sup>3</sup> /h	1.191	1.189	506	1.021	1.191	516	516	
% Capacity	%	99,4%	99,4%	99,4%	99,4%	99,4%	99,4%	99,4%	
Operating displacement	m <sup>3</sup> /h	1.184	1.182	503	1.015	1.184	513	513	
Density NH <sub>3</sub> (@11,5bar / 60°C)	kg/m <sup>3</sup>	7,71	7,71	7,71	7,71	7,71	7,71	7,71	
NH <sub>3</sub> Mass rate	kg/h	9.130	9.117	3.881	7.828	9.130	3.956	3.956	
Specific heat capacity	kJ/kg*K	2,75	2,75	2,75	2,75	2,75	2,75	2,75	
Average NH <sub>3</sub> Temperature	°C	60	60	60	60	60	60	60	
Ambient temperature	°C	30	30	30	30	30	30	30	
Delta T	K	30	30	30	30	30	30	30	
Waste heat flow	kJ/h	751.852	750.779	319.613	644.599	751.846	325.737	325.737	
<b>Potential thermal output</b>	<b>kW<sub>th</sub></b>	<b>209</b>	<b>209</b>	<b>89</b>	<b>179</b>	<b>209</b>	<b>90</b>	<b>90</b>	<b>1.075</b>
Full Load Hours (90% utilisation)	h/a	6.400	1.400	3.800	5.000	4.200	4.400	4.400	
Heat Exchanger Eff.	%	72%	72%	72%	72%	72%	72%	72%	
Energy Potential	MWh <sub>th</sub> /a	962	210	243	645	632	287	287	<b>3.265</b>
Energy Price	USD/kWh <sub>th</sub>	0,08	0,08	0,08	0,08	0,08	0,08	0,08	
Monetary Saving Potential	USD/a	76.990	16.817	19.432	51.568	50.524	22.932	22.932	<b>261.195</b>
Water heat-up equ. (30-60°C)	m <sup>3</sup> /a	27.562	6.021	6.957	18.461	18.087	8.209	8.209	<b>93.507</b> 14%
Bunker equ. (42,8 kWh/gal, 82%eff.)	gal/a	22.501	4.915	5.679	15.071	14.766	6.702	6.702	<b>76.336</b> 11%



In-built PSHE by Vahterus

- Analysis of the real load curve required to determine best available heat recovery potential
- Estimated investment for PSHE: 80.000 USD and annual OPEX saving of 260.000 USD
- Energy Saving potential of 3.265 MWh/a or an equivalent of 289.000 l/a HFO (11% of total HFO)
- CO<sub>2e</sub> mitigation potential of 1.011 t CO<sub>2e</sub>




# | Insulation of tubes

	[Unit]	Status Quo	1.5"	2.0"	2.5"	3.0"
Total heat loss	kWh <sub>th</sub> /a	<b>70.648</b>	10.583	9.180	8.236	7.553
Energy consumption	kWh/a	86.156	12.906	11.195	10.044	9.211
<b>Energy savings</b>	<b>kWh/a</b>		<b>73.251</b>	<b>74.962</b>	<b>76.112</b>	<b>76.945</b>
Energy costs	USD/a	6.893	1.032	896	804	737
<b>Cost savings</b>	<b>USD/a</b>		<b>5.860</b>	<b>5.997</b>	<b>6.089</b>	<b>6.156</b>
Total CO <sub>2e</sub> Emissions	t CO <sub>2</sub> /a	25	4	3	3	3
<b>Insulation + Installation</b>	<b>USD</b>		<b>6.300</b>	<b>6.800</b>	<b>8.200</b>	<b>9.700</b>
<b>Simple PBP</b>	<b>a</b>		<b>1,08</b>	<b>1,13</b>	<b>1,35</b>	<b>1,58</b>




Example: Mineral rock with aluminum coating

**Calculation assumptions:** Ambient temperature of 35°C; Feed water temperature of 85°C; pipe material 2" STD Stainless Steel (304 L); length of pipes: 100 m; 82% Boiler Efficiency; heat price of 0.08 USD/kWh<sub>th</sub>









## Recommendation:

- Mapping all thermal (exhaust) processes, e.g.
  - Exhaust of Boilers
  - Heat Exchangers
  - Waste Water
  - Compressors
  - NH<sub>3</sub> Cooling
- Determine heat re-utilization (sinks) options at different temperature levels





# | Utilization of e-forklifts



High  
Performance



Energy Efficiency  
& GHG avoidance



Safety

- Maintenance-free and wear-free motors in 3-phase technology
- OHAS: significant reduction on noise, dissipative heat and LPG handling
- Service (and experience) in host country available
- Economically interesting if LCOE Renewables is below LCOE of LPG
- GHG abatement if PV-powered

Drive motor, power	4 kW
Lift motor	6 kW
Battery capacity	24/500 V/Ah
Energy consumption	2.6 kWh/h
Approx. cost	Reg. CAPEX + 20K USD as of 2020

# Utilization of e-forklifts



Comparison of LPG vs Electric forklifts				
Parameter	Unit	LPG forklift	Electric forklift	
			Grid electricity	Photovoltaic
Energy consumption	kWh/h	21,34	3,61	3,61
Fuel consumption	l/h	3,92		
Energy price*	USD/kWh	0,10	0,15	0,09
Annual operating hours	h/a	1.800	1.800	1.800
Annual energy consumption	kWh/a	38.407	6.500	6.500
Annual energy savings	kWh/a		31.907	31.907
Annual energy costs	USD/a	3.839	969	585
Annual cost savings	USD/a		2.870	3.254
Additional CAPEX e-forklifter	USD		20.000	20.000
GHG emissions	t CO <sub>2e</sub> /a	8,7	4,9	
Annual GHG savings	t CO <sub>2e</sub> /a		3,9	8,7
Simple payback additional CAPEX	a		7,0	6,1

\*Client Data: Weighted average energy price for LPG (based on consumption) and LCoE-PV

# e-forklifts – Scenario 2025



Comparison of LPG vs Electric forklifts				
Parameter	Unit	LPG forklift	Electric forklift	
			Grid electricity	Photovoltaic
Energy consumption	kWh/h	21,34	3,61	3,61
Fuel consumption	l/h	3,92		
Energy price (LPG + 5%/y / PV declined)	USD/kWh	0,12	0,15	0,06
Annual operating hours	h/a	1.800	1.800	1.800
Annual energy consumption	kWh/a	38.407	6.500	6.500
Annual energy savings	kWh/a		31.907	31.907
Annual energy costs	USD/a	4.666	969	390
Annual cost savings	USD/a		3.697	4.276
CAPEX e-forklifter - 50%	USD		10.000	10.000
GHG emissions	t CO <sub>2e</sub> /a	8,7	4,9	
Annual GHG savings	t CO <sub>2e</sub> /a		3,9	8,7
Simple payback additional CAPEX	a		2,7	2,3

\*Client Data: Weighted average energy price for LPG (based on consumption) and LCoE-PV

# | (Electrical) Rapid Steam Generator



- Instant steam generation according to demand (from 3 up to 11 bar)
- Quick reaction for fluctuating steam requirements (8 kg/h up to 160 kg/h) – option for steam cascading
- More efficient than LPG or Natural Gas boilers at lower or no steam consumption (modulation from 40% up to 100%)

Technical details			
Parameter	Unit	E 6 M - E 72 M	E 100 M - E 120 M
Steam output	kg/h	8 - 97	
Heat output	kW	Jun 72	
Electrical connection value	kW	6.8 - 73.8	
Height / Width / Depth	mm	1,850/880/680	1,925/1.005/800
Max. operating pressure	bar	3.5 - 11	5 - 10
Max. perm. overpressure	bar	6 / 10 / 12	6 / 10 / 12
Average equipment price	USD	12,000 - 100,000	



# (Electrical) Rapid Steam Generator

- Instant steam generation according to demand (from 3 up to 11 bar)



Levelized cost of steam - Economic comparison HFO vs Electricity				
Parameter	Unit	HFO	Electricity	
			National Grid	Photovoltaic
Energy content (NCV)	kWh/l	11,2		
Density	kg/m <sup>3</sup>	840		
Emission factor (Primary Energy)	kg CO <sub>2e</sub> /kWh	0,28	0,712	
Net fuel price	USD/l	0,52		
Net fuel price	USD/kWh	0,046	0,149	0,09
spec. Total Enthalpy of steam (@7 barG)	kJ/kg <sub>steam</sub>	2.375		
spec. Total Enthalpy of steam (@7 barG)	kWh/t <sub>steam</sub>	660		
Boiler Efficiency	η	82 %	98 %	98 %
Steam distribution efficiency	%	92 %	99 %	99 %
End energy demand for steam generation	kWh/t <sub>steam</sub>	874,87	680,27	680,27
Levelised costs of steam (excl. CAPEX)	USD/t <sub>steam</sub>	40,55	101,36	61,22
GHG emission level	kg CO <sub>2e</sub> /t <sub>steam</sub>	244,96	484,35	0*






- Price increase HFO + 5%/y versus declining LCoE-PV

Levelized cost of steam – Economic comparison HFO vs Electricity – 2025				
Parameter	Unit	HFO	Electricity	
			National Grid	Photovoltaic
Energy content (NCV)	kWh/l	11,2		
Density	kg/m <sup>3</sup>	840		
Emission factor (Primary Energy)	kg CO <sub>2e</sub> /kWh	0,28	0,712	
Net fuel price	USD/l	0,52		
Net fuel price	USD/kWh	0,056	0,149	0,06
spec. Total Enthalpy of steam (@7 barG)	kJ/kg <sub>steam</sub>	2.375		
spec. Total Enthalpy of steam (@7 barG)	kWh/t <sub>steam</sub>	660		
Boiler Efficiency	η	82 %	98 %	98 %
Steam distribution efficiency	%	92 %	99 %	99 %
End energy demand for steam generation	kWh/t <sub>steam</sub>	874,87	680,27	680,27
Levelised costs of steam (excl. CAPEX)	USD/t <sub>steam</sub>	49,28	101,36	40,82
GHG emission level	kg CO <sub>2e</sub> /t <sub>steam</sub>	244,96	484,35	0*

# Ozone CIP compact system [ 120x80x270 cm]

- Cut CIP cycle time by 20-30 minutes due to shorter sanitation and rinse-free operation
- Eliminate all disinfection agents used for treatment or sanitation
- Reduce (HFO-steam based) energy requirements by replacing hot water with cold ozone sanitation
- No handling of chemicals, transport and costs
- Chemical-free feed and process water quality assurance



<https://www.ozonetech.com/>



Left: RENA Vivo B-series front. Right: RENA Vivo B-series back.


Static, mechanical  
egg shaped



Classical



Flat design



Different construction design results in different

- CAPEX (800 bis 2.000 EUR/m<sup>3</sup>)
- OPEX
- Maintenance



Quelle: Neubewertung von Abwasserreinigungsanlagen mit anaerober Schlammbehandlung vor dem Hintergrund der energetischen Rahmenbedingungen und der abwassertechnischen Situation in Rheinland-Pfalz - NAWaS Modul 2: Weitergehende Untersuchungen

Quelle: Fraunhofer IGB (2012): Abschlussbericht – Voruntersuchungen zur anaeroben Vergärung von Primär- und Sekundärschlamm der GKA Weilerbach

# | Increasing biogas production sludge digestion

DM-content	DM-%	Amount [m <sup>3</sup> /d]	DM [m <sup>3</sup> /d]
Primary sludge	5%	118,4	5,9 m <sup>3</sup> /d
Secondary sludge	5%	341,4	17,1 m <sup>3</sup> /d
<b>Total</b>	<b>5,00%</b>	<b>459,8</b>	<b>23,0 m<sup>3</sup>/d</b>

oDM-content	oDM-%	oDM
Primary sludge	67%	4 m <sup>3</sup> /d
Secondary sludge	70%	12 m <sup>3</sup> /d

Methane content (based on oDM)	I <sub>N</sub> /kg oDM	Biogas production	Methan-rate %	Methan production
Primary sludge (54%)	400	1.586 m <sup>3</sup> /d	60%	952 m <sup>3</sup> /d
Secondary sludge (59%)	400	4.780 m <sup>3</sup> /d	60%	2.868 m <sup>3</sup> /d
<b>Total per day</b>		<b>6.366 m<sup>3</sup>/d</b>	60%	<b>3.820 m<sup>3</sup>/d</b>
<b>Total per year</b>		<b>2.100.789 m<sup>3</sup>/a</b>		<b>1.260.473 m<sup>3</sup>/a</b>

Volume of the digester		
Hydraulic retention time	20	d
DM sludge	5,00%	
Volume Sludge	460	m <sup>3</sup> /d
<b>Volume digester</b>	<b>9.196</b>	<b>m<sup>3</sup></b>

## Objective:

Complement UASB reactor **with second fermenter** for anaerobic stabilization of the activated (primary and secondary) sludge

- **635% biogas production increase** from 1.191 Nm<sup>3</sup> to 7,557 Nm<sup>3</sup> per day
- Follow-up potential





## Strategic approach of fossil fuel switch [steam generation]:

- Reduction of steam demand (and thermal energy losses)
- Utilising excess heat by auxiliary technologies (Compressed air and ammonia cooling compressors)
- Increasing biogas production and utilisation in bi-fuel boiler
- Acquire new biogenic fuels for existing boilers
- Introduce point of demand e-steam




# Final Results

## Transformation Pathway 2050

**KFW** DEG

**IfaS**

# | Exemplified net-zero trajectory



2023-25: Production increase & constant WACI

“Must have” efficiency projects reducing WACI and continuous efficiency improvement

Strategic projects:

- Expansion of RE (biogas & PV);
- Stepwise HFO-steam replacement powered by RE;
- Expansion of e-mobility based distribution
- Securing carbon removal certificates
- Battery based peak load shaving
- Green Hydrogen and Wind energy

Start (partly) neutralising GHG (sourcing until 2024)  
(MAC internal > cost of removal)

# DeCarbonisation Pathway – MODEL Result

Year	Total production	Total Emissions [Transformation] [Scope 1 and 2]	Weighted average Carbon intensity
	hl	t CO <sub>2e</sub> /a	kg/CO <sub>2e</sub> /hl
2021	3,381,724	35,378	10.46
2022	3,514,626	35,543	10.11
2023	3,652,751	34,260	9.38
2024	3,796,304	33,123	8.73
2025	3,945,498	28,024	7.10
2026	4,100,556	28,474	6.94
2027	4,261,708	28,767	6.75
2028	4,429,193	28,690	6.48
2029	4,603,261	28,615	6.22
2035	5,801,111	20,761	3.58
2038	6,512,293	12,564	1.93
2040	7,034,217	12,039	1.71

## KPI development of Paris-aligned net-zero pathway:

- CAGR of 3,93 % = Double the production until 2040
- Emission base year (2022): 35.543 tCO<sub>2e</sub>
- Emission net-zero (2040): 12.039 tCO<sub>2e</sub>
- Absolute GHG reduction: 66%
- Relative GHG reduction: 84%  
(based on 73.588 tCO<sub>2e</sub> in CAGR scenario)
- WACI Reduction: 84%
- Annual GHG removal cost saving: 6.921.071 USD  
(based on 73.588 tCO<sub>2e</sub> in CAGR scenario and 581 USD/tCO<sub>2e</sub> in EIB scenario)

# Contribution to SDGs (impact assessment)







Dr. Michael Knaus

Institut für angewandtes Stoffstrommanagement (IfaS)

Umwelt-Campus Birkenfeld  
Campusallee  
55768 Hoppstädten-Weiersbach

Email: [m.knaus@umwelt-campus.de](mailto:m.knaus@umwelt-campus.de) and [f.flesch@umwelt-campus.de](mailto:f.flesch@umwelt-campus.de)